

Complex dynamics of blackouts in power transmission systems

B. A. Carreras and V. E. Lynch

Oak Ridge National Laboratory, Oak Ridge, Tennessee 37831

I. Dobson

Electrical and Computer Engineering Department, University of Wisconsin, Madison, Wisconsin 53706

D. E. Newman

Physics Department, University of Alaska, Fairbanks, Alaska 99775

(Received 27 August 2003; accepted 21 June 2004; published online 1 September 2004)

In order to study the complex global dynamics of a series of blackouts in power transmission systems a dynamical model of such a system has been developed. This model includes a simple representation of the dynamical evolution by incorporating the growth of power demand, the engineering response to system failures, and the upgrade of generator capacity. Two types of blackouts have been identified, each having different dynamical properties. One type of blackout involves the loss of load due to transmission lines reaching their load limits but no line outages. The second type of blackout is associated with multiple line outages. The dominance of one type of blackout over the other depends on operational conditions and the proximity of the system to one of its two critical points. The model displays characteristics such as a probability distribution of blackout sizes with power tails similar to that observed in real blackout data from North America.

© 2004 American Institute of Physics. [DOI: 10.1063/1.1781391]

Power transmission systems are complex systems that evolve over years in response to the economic growth of the country and to continuously increasing power demand. In spite of the reliability of these systems, there are widespread disturbances that have significant cost to society. The average frequency of blackouts in the United States is about one every 13 days. This frequency has not changed over the last 30 years. Also the probability distribution of blackout sizes has a power tail; this dependence indicates that the probability of large blackouts is relatively high. Indeed, although large blackouts are rarer than small blackouts, it can be argued that their higher societal cost makes the risk of large blackouts comparable to or exceed the risk of small blackouts. The operation of power transmission systems is studied from the perspective of complex dynamics in which a diversity of opposing forces regulate both the maximum capabilities of the system components and the loadings at which they operate. These forces enter in a nonlinear manner and may cause an evolution process to be ultimately responsible for the regulation of the system. This view of a power transmission system considers not only the engineering and physical aspects of the power system, but also the economic, regulatory, and political responses to blackouts and increases in load power demand. From this perspective, the search for the cause of the blackouts must not be limited to the trigger of the blackout, which is normally a random event, but it must also consider the dynamical state of the power transmission system. A detailed incorporation of all these aspects of the dynamics into a single model is extremely complicated. Here, a simplified model is discussed with some approximate overall

representation of the opposing forces controlling the system dynamics. This model reproduces some of the main features of North American blackout data.

I. INTRODUCTION

Power transmission systems are complex systems that evolve over years in response to the economic growth of the country and to continuously increasing power demand. The evolution and reliability of these systems are leading engineering accomplishments of the last century that underpin developed societies. Nevertheless, widespread disturbances of power transmission systems that have significant cost to society are consistently present. An analysis of blackouts¹ done in the 1970s indicated that the average frequency of blackouts in the United States was one every 14 days. More recent analyses^{2,3} of 15 years of North American Electrical Reliability Council (NERC) data on blackouts of the North American power grid⁴ gave an average frequency of blackouts of one every 13 days. Furthermore, these analyses show that the distribution of blackout sizes has a power tail with an exponent of about -1.3 ± 0.2 . These results indicate that the probability of large blackouts is relatively high. Indeed, although large blackouts are rarer than small blackouts, it can be argued that combining their higher societal costs with their relatively high probability makes the risk of large blackouts comparable to or greater than the risk of small blackouts.⁵

It is clear that individual blackouts are triggered by random events ranging from equipment failures and bad weather to vandalism.⁴ The blackouts then typically become widespread through a series of cascading events. However, it must be remembered that these individual blackouts occur in

a power transmission system that is itself slowly and dynamically evolving in its design, configuration, and operation. For example, the loading of system components relative to their maximum loading is a key factor governing the propagation of component failures and this loading evolves as the system components or operational policies are upgraded. The existence of a power tail in the distribution of blackouts and the long time correlations seen in the system suggests that underlying the large-scale blackouts may be a dynamically caused proximity to a critical point. It should be noted that the size of a given blackout is unrelated to the particular triggering event that initiated that blackout.

To investigate such a possibility, we propose a model for power transmission systems^{6,7} that involves not only the dynamics of the generator dispatch but also the evolution of the system under a continuous increase in demand. This model shows how the slow opposing forces of load growth and network upgrades in response to blackouts could self-organize the power system to a dynamic equilibrium. Blackouts are modeled by overloads and outages of transmission lines determined in the context of linear programming (LP) dispatch of a dc load flow model. This model shows complex dynamical behaviors and has a variety of transition points as a function of increasing power demand.⁸ Some of these transition points have the characteristic properties of a critical transition. That is, when the power demand is close to a critical value, the probability distribution function (PDF) of the blackout size has an algebraic tail, and the system changes sharply across the critical point. Because of this, the risk of a global blackout increases sharply at the critical transition.

The fact that, on one hand, there are critical points with maximum power flow through the network and, on the other hand, there is a self-organization process that tries to maximize efficiency and minimize risk, may lead to a power transmission model governed by self-organized criticality (SOC).⁹ Such a possibility was first explored with a simple cellular automaton model¹⁰ that incorporates neither the circuit equations nor the type of long-term dynamics discussed above. In this paper, we study the dynamical properties of a power transmission model^{6,7} that does incorporate these two components.

There have been some other complex system approaches to modeling aspects of power system blackouts. In the most closely related work, Chen and Thorp^{11,12} modeled power system blackouts using dc load flow and LP dispatch and represented in detail hidden failures of the protection system. They obtained the distribution of power system blackout size by rare event sampling, and studied blackout risk assessment and mitigation methods. Stubna and Fowler¹³ applied a modified “Highly Optimized Tolerance” (HOT) model to fit North American blackout data for blackout sizes measured by both power shed and customers disconnected. Using a different approach, Roy, Asavathiratham, Lesieutre, and Verghese constructed randomly generated tree networks that abstractly represent influences between idealized components.¹⁴ In that work, components can be failed or operational according to a Markov model that represents both internal component failure and repair processes and in-

fluences between components that cause failure propagation. The effects of the network degree of connectivity and inter-component influences on the failure size and duration were studied. Similarly, Pepyne *et al.*¹⁵ used a Markov model for discrete-state power system nodal components but had failures propagate along the transmission lines of a power system network with a fixed probability. DeMarco¹⁶ and Parrilo *et al.*¹⁷ addressed the challenging problem of determining cascading failure due to dynamic transients by using hybrid nonlinear differential equation models. DeMarco used Lyapunov methods applied to a smoothed model; Parrilo *et al.* used Karhunen–Loeve and Galerkin model reduction to address the problem.

The rest of this paper is organized as follows: In Sec. II, we introduce a dynamical model of power transmission system evolution over long time scales. Details of the power flow model and of the fast time scale dynamics are provided in the Appendix. In Sec. III, numerical results of the model are reported with an analysis of the time and space correlations introduced by the dynamics. In Sec. IV, we analyze the effect of changing the ratio of generator capacity margin to maximum load fluctuation. This ratio allows the separation of the dynamics into two different regimes. The conclusions are given in Sec. V.

II. DYNAMICAL MODEL FOR POWER TRANSMISSION

In modeling the dynamics of power transmission systems, one must consider two intrinsic time scales. There is a slow time scale, of the order of days to years, over which load power demand slowly increases. Over this time scale, the network is upgraded in engineering responses to blackouts and in providing more generator power in response to demand. As we shall see, these slow opposing forces of load-increase and network-upgrade self-organize the system to a dynamic equilibrium. The dynamical properties of this model are the main topic of this paper. In power transmission systems, there is also a fast time scale, of the order of minutes to hours, over which power is dispatched through the network within which (depending on the conditions of the network) cascading overloads or outages may lead to a blackout.

Over the fast time scale, we solve the standard dc power flow equation for a given distribution of load demand. We use the standard LP method^{18–20} with the usual constraints on generating power capability and transmission line limits to solve the generator power dispatch. An example of a power transmission network used in these studies is the IEEE 118 bus network²¹ shown in Fig. 1. Details of the fast dynamics can be found in Refs. 6 and 7 and a summary description is given in the Appendix.

In any network, the network nodes (buses) are either loads (L) (black squares in Fig. 1), or generators (G), (gray squares in Fig. 1). The power P_i injected at each node is positive for generators and negative for loads, and the maximum power injected is P_i^{\max} . The transmission line connecting nodes i and j has power flow F_{ij} , maximum power flow F_{ij}^{\max} , and impedance z_{ij} . There are N_L lines and $N_N = N_G + N_L$ total nodes, where N_G is the number of generators and N_L is the number of loads.



FIG. 1. Diagram of the IEEE 118 bus network. Generators are gray squares; loads are the black squares.

The slow dynamics proposed in Refs. 6 and 7 has three components: (1) the growth of the demand, (2) response to blackouts by upgrades in the grid transmission capability, and (3) response to increased demand by increasing maximum generator power. These components of the model are translated into a set of simple rules. We simplify the time scale by regarding one blackout to be possible each day at the peak loading of that day. At the beginning of the day t , we apply the following rules:

- (1) The demand for power grows. All loads are multiplied by a fixed parameter λ that represents the daily rate of increase in electricity demand. On the basis of past electricity consumption in the United States, we estimate that $\lambda = 1.00005$. This value corresponds to a yearly rate of 1.8%,

$$P_i(t) = \lambda P_i(t-1) \text{ for } i \in L. \quad (1)$$

To represent the daily local fluctuations in power demand, all power loads are multiplied by a random number r , such that $2 - \gamma \leq r \leq \gamma$, with $1 \leq \gamma \leq 2$. The power transmission grid is improved. We assume a gradual improvement in the transmission capacity of the grid in response to outages and blackouts. This improvement is implemented through an increase of F_{ij}^{\max} for the lines that have overloaded during a blackout. That is,

$$F_{ij}^{\max}(t) = \mu F_{ij}^{\max}(t-1), \quad (2)$$

if the line ij overloads during a blackout. We take μ to be a constant greater than 1 and in the present studies we have varied μ in the range $1.01 \leq \mu \leq 1.1$.

It is customary for utility engineers to make prodigious efforts to avoid blackouts, and especially to avoid repeated blackouts with similar causes, which we have simplified into this one parameter μ . In general, these responses to blackouts occur on a range of time scales longer than one day. Responses include repair of damaged equipment, more frequent maintenance, changes in operating policy away from the specific conditions causing the blackout, installing new equipment to increase system capacity, and adjusting or adding system alarms or controls. The responses reduce the probability of events in components related to the blackout, either by

lowering their probabilities directly or by reducing component loading by increasing component capacity or by transferring some of the loading to other components. The responses are directed toward the components involved in causing the blackout. Thus the probability of a similar blackout occurring is reduced; at least until load growth degrades the improvements that were made. There are similar but less intense responses to unrealized threats to system security, such as near misses and simulated blackouts.

By simplifying all engineering responses into a single parameter μ we crudely represent all these responses to a blackout. The response is modeled as happening on the next day, but the effect is eventually cancelled by the slow load increase. Because of the disparity between these two time scales, at this level of modeling it does not seem crucial to have an accurate estimate of the response time, and the one-day time scale may be reasonable.

- (2) The maximum generator power is increased in response to the load demand as follows:

- (a) The increase in power is quantized. This can reflect either the upgrade of a power plant or the addition of generators. The increase is taken to be a fixed ratio to the total power. Therefore, we introduce the quantity

$$\Delta P_a \equiv \kappa (P_T / N_G), \quad (3)$$

where P_T is the total power demand, N_G the number of generators, and κ is a parameter that we have taken to be a few percent.

- (b) To be able to increase the maximum power in node j , the sum of the power flow limits of the lines connected to j should be larger than the existing generating power plus the addition at node j . This requirement maintains the coordination of the maximum generator power ratings with the line ratings.

- (c) A second condition to be verified before any maximum generator power increase is that the mean generator power margin has reached a threshold value. That is, we define the mean generator power margin at a time t as

$$\frac{\Delta P}{P} = \frac{\sum_{j \in G} P_j - P_0 e^{(\lambda-1)t}}{P_0 e^{(\lambda-1)t}}, \quad (4)$$

where P_0 is the initial power load demand.

- (d) Once condition (c) is verified, we choose a node at random to test condition (b). If the chosen node verifies condition (b), we increase its power by the amount given by Eq. (3). If condition (b) is not verified, we choose another node at random and iterate. After power has been added to a node, we use Eq. (4) to recalculate the mean generator power margin and continue the process until $\Delta P/P$ is above the prescribed quantity $(\Delta P/P)_c$.

- (3) We also assign a probability p_0 for a random outage of a line. This value represents possible failures caused by phenomena such as accidents and weather related events.

After applying these three rules to the network, we look for a solution of the power flow problem by using linear programming as described in the Appendix.

It is also possible to introduce a time delay between the detection of a limit in the generation margin and the increase in maximum generator power. This delay would represent construction time. However, the result is the same as increasing the value of κ in Eq. (3), which can also give an alternative interpretation for κ .

Five basic parameters control the dynamics of this model. One is the rate of increase in power demand, λ , which we keep fixed at 1.8% per year on the basis of the averaged value for the U.S. grid in the last two decades.²² A second parameter is the improvement rate of the transmission grid, μ . This is not an easy parameter to estimate. However, once μ is given, there is a self-regulation process by which the system produces the number of blackouts that would stimulate the engineering response needed to meet demand. This is a necessary condition for the dynamical equilibrium of the system. The rate of increase in power demand for the overall transmission system is essentially given by $R_D \approx (\lambda - 1)N_L$. The system response is $R_R \approx (\mu - 1)f_{\text{blackout}} \langle \ell_o \rangle N_L$, where f_{blackout} is the frequency of blackouts and $\langle \ell_o \rangle$ is a weighted average of the number of lines overloaded during a blackout. Dynamical equilibrium implies that $R_D = R_R$. That is, the increase in demand and the corresponding increase in power supply must be matched by improvements in the transmission grid. Because those improvements are in response to real or simulated blackouts, this relation implies that μ must be greater than λ ; otherwise, the system would be collapsing with constant blackouts. In the numerical calculations and for the value of the demand increase of 1.8% per year, we found that μ must be > 1.01 in order to avoid this collapse regime. In the present calculations, we keep μ in the range 1.01–1.1. In this regime, results depend weakly on μ .

A third parameter Γ is a measure of the generation capacity of the power system in response to fluctuations in the power demand. Γ is the ratio of the reserve generator power to the maximum daily fluctuation of the power demand. The averaged power demand increases exponentially in time as $\bar{P}_D(t) \equiv P_0 e^{(\lambda - 1)t}$. However, the real instantaneous demand is $P_D(t)$, different from the averaged power demand because of daily fluctuations. The generator power installed $P_G(t)$ is also different from the averaged power demand. The difference $\Delta P(t) \equiv P_G(t) - \bar{P}_D(t)$ is the generator capability margin used to cope with fluctuations in power demand. In our calculations, the generator capability margin is varying in time, but we require it to be larger than a minimum prescribed value ΔP_c . Because the power demand is continuously increasing, it is convenient to normalize all these quantities to $\bar{P}_D(t)$. Thus we define Γ as the ratio of the normalized minimal generator capability margin $\Delta P_c / \bar{P}_D(t)$ to the maximum fluctuation of the load demand $g \equiv \max[(P_D(t) - \bar{P}_D(t)) / \bar{P}_D(t)]^{1/2}$,

$$\Gamma = [\Delta P_c / \bar{P}_D] / g. \quad (5)$$

There is a simple relation between g and the load fluctuation parameter γ . The parameter Γ is the main parameter varied in the calculations presented here. In the U.S., the generator power capability margin has had a wide variation over the years, but an estimated mean value²² falls into the range of 15%–30%.

The fourth parameter is the probability of an outage caused by a random event (p_0). This parameter can be used to partially control the frequency of blackouts, although the relation between them is not linear. The fifth parameter is the probability for an overloaded line to undergo an outage (p_1). We keep this parameter in the range $0.1 \leq p_1 \leq 1.0$.

Since each calculation can be done for different specific network configurations, in this work we will use idealized treelike networks, which were discussed in Ref. 8, as well as more realistic networks, such as the IEEE 118 bus network depicted in Fig. 1.

The time evolution of a power transmission system represented by this model leads, after a transient, to a steady-state regime. Here “steady state” is defined with relation to the slow dynamics of the blackouts because the power demand is constantly increasing, as shown in Fig. 2. The time evolution in the model shows the transient period followed by steady-state evolution. This is illustrated in Fig. 2, where we have plotted the number of blackouts per 300 days as a function of time. We can see a slight increase in the average number of blackouts during the first 20 000 days. This transient period is followed by the steady state where the number of blackouts in an averaged sense is constant. The properties in the slow transient are not very different from those in the steady state. However, for statistical analysis, we use the steady-state information to avoid contamination of the statistics. The length of the transient depends on the rate of growth in power demand. In the following calculations, we evaluate the blackout statistics by ignoring the initial transients and doing the calculations for a time period of 80 000 days in a steady state. Of course, the use of these long time scale steady-state results is driven by the need for large statistical samples and it is arguable whether the real electric power grid ever actually reaches a steady state.

III. DYNAMICAL EVOLUTION OF THE POWER TRANSMISSION MODEL

Looking at the time evolution of the different parameters that characterize the blackouts, one observes a noisy signal that could be mistaken for random. One could assume that this is in fact the situation because many of the blackouts are triggered by random events with probability p_0 . However, that is not the case. It is instead found that there are significant space and time correlations resulting from the underlying dynamics of the power transmission model.

To investigate the time correlations in this apparently noisy system we calculate the Hurst exponent²³ of time series of blackout sizes. Here, we consider two measures of the size of a blackout. One is the load shed during a blackout normalized to the total power demand; the other is the number of line outages during a blackout.




FIG. 2. (Color) Time evolution of the power served and number of blackouts per year from the model.

We use the R/S method²⁴ to calculate the Hurst exponent. An example of the result of this analysis is shown in Fig. 3. For times of the order of a few days and a few years, both series show weak persistence. They have the same Hurst exponent ($H=0.55\pm 0.02$). This result is close to the one obtained in the analysis² of NERC data on blackouts of




FIG. 3. (Color) R/S for the time series of normalized load shed and line outages for a 46-node tree network.




FIG. 4. (Color) The Hurst exponent H as a function of Γ for the time series of normalized load shed (a) and line outages (b). The exponent is calculated from a fit of R/S in the time range $600 \leq t \leq 10^5$ for 46, 94, and 190 nodes tree networks and for the IEEE 118 bus network.

the North American power grid.⁴ In this range of time scales, the value of the exponent does not depend on the value of Γ . For longer times, each time series shows a different behavior. The load shed has a nearly random character with $H=0.5$ for $\Gamma < 1$. For $\Gamma > 1$, the value of H decreases and in many cases is below 0.5. For these longer time scales, the time series of the number of line outages has a clear antipersistent character with H ranging from 0.2 to 0.4, depending on the network structure. In Fig. 4, the value of H resulting from a fit of R/S

in the time range $600 \leq t \leq 10^5$ is given as a function of Γ for three of the tree networks and for the IEEE 118 bus network. Antipersistence in the time sequence of number of line outages can be expected from the model. Blackouts with a large number of line outages happen rarely, only once every few years. When they happen, there is a great deal of repair and enhancement of many transmission lines. As a consequence, blackouts with a large number of line outages become less probable after one of those events. Therefore, there is antipersistence at that time scale. In the present model, load shed does not have a direct impact on the repair and upgrade of the system. Therefore, time correlations are weak. As we will discuss in the next section, for $\Gamma > 1$, blackouts with large load sheds are associated with a large number of line outages. Therefore, in this Γ range we see some level of antipersistence due to the coupling of load shed and the number of line outages. The available data from NERC are limited to 15 years, and we therefore do not have any direct way of confirming this long-term behavior of the model in the real power system.

The time lag during which the number of line outages changes from weak persistency to antipersistence is independent of the network size but depends on the repair rate (μ). As μ increases, it takes longer time lags for the change to occur. Increasing μ causes a slight increase in H , but H remains less than 0.5.

Within this model the correlations are not limited to time correlations. The PDFs of the load shed and the number of line outages both have power-scaling regions implying spatial correlations. The correlations responsible for these power tails are the result of the system being near a critical point.

In Ref. 7, we studied the critical points of the power transmission model as the total load demand was varied. The slow dynamics described in Sec. II were not modeled. We found two types of critical points: one type was related to the limiting power flows in the transmission lines; the other type was related to the limit in the power generation. When these types of critical points are close to each other, the probability distribution of the blackout size as measured by the amount of load shed has a power law dependence for a range of values of the load shed. Away from the critical point, this power law dependence no longer exists.

When the dynamical evolution over long time scales is included and the value of Γ is about 1, the system naturally evolves to a situation in which these critical points are close to each other. In this situation, the PDFs of the power shed will have a region of algebraic decay. In Fig. 5, we have plotted the relative cumulative frequency calculated from the time series of the blackout data from the numerical results. The cumulative frequency has been calculated directly from these data using the rank function. In Fig. 5, the load shed is normalized to the total power demand. The calculation was done for three of the tree network configurations. These distributions are compared with those obtained from a load scan without dynamical evolution when the load value was at the critical point. We cannot distinguish between the two calculations; the relative cumulative frequencies are practically the same. The overlap between the two results indicates that the dynamical model described in Sec. II intrinsically leads

to operation of the system close to the critical points. A similar result has been obtained for the IEEE 118 bus network. In Fig. 5, we have given an arbitrary shift to the relative cumulative frequencies for a given size network to better observe the three different cases.

The relative cumulative frequency plotted in Fig. 5 has three characteristic regions. They all have an exponential tail reflecting the finite size effect of the network (region III). Region II is characterized by an algebraic decay. This power-law-scaling region increases with the number of nodes in the network, suggesting that it is a robust feature of the system. The power decay index is practically the same for the four networks and is close to -0.55 . The particular values of the decay index for each tree network are given in Table I, in which the range of the power tail region is defined as the ratio of the maximum load shed to the minimum load shed described by the power law. From the values obtained for the four networks listed in Table I, we can see that this range scales with the network size.

The functional form of the relative cumulative frequency, or at least their power-scaling region, seems to have a universal character. Therefore, we can compare the relative cumulative frequency of the normalized load shed obtained for the largest network with the relative cumulative frequency of the blackouts obtained in the analysis of the 15 years of NERC data.⁴ In Fig. 6, we have plotted the relative cumulative frequency of the NERC data together with the relative cumulative frequencies for the 382-node tree and IEEE 118 bus networks. We have normalized the blackout size to the largest blackout over the period of time considered. We can see that the present model, regardless of the network configuration, reproduces quite well the power-scaling region from the NERC data. The size of this region is shorter for the calculations. This is because the calculations are done for relatively small networks. The level of agreement between the algebraic scaling regions of the relative cumulative frequencies is remarkable and indicates that the dynamical model for series of blackouts has captured some of the main features of the NERC data.

IV. DYNAMICAL REGIMES

Calculations carried out with this model show the existence of two different dynamical regimes. The first regime is characterized by the low value of Γ (that is, a low generator capability margin and/or large fluctuations in the power demand). In this regime, the available power is limited and has difficulties in meeting demand. Blackouts are frequent, but they affect only a limited number of loads. In this regime, there are very few line outages. In the opposite limit, Γ is large and the blackouts are less frequent, but they tend to involve multiple line outages when they happen. This latter regime is interesting because there are many cascading events that can cause blackouts in a large part of the network. This suggests a possible separation between regimes of few failures and regimes with cascading failures both of which are physically interesting.

Let us investigate in a quantitative way the separation between these two regimes by varying the parameter Γ .




FIG. 5. (Color) Relative cumulative frequency of the load shed normalized to the total power demand for three different tree networks. The relative cumulative frequencies obtained from a load scan near the critical point are compared with the relative cumulative frequencies obtained from the dynamical model discussed in this paper.




FIG. 6. (Color) Relative cumulative frequencies of the normalized load shed for the 382-node tree, the IEEE 118 bus networks, and the North American blackouts in 15 years of NERC data normalized to the largest blackout.

Varying Γ is not necessarily a realistic way of modeling the transmission system but it allows us to understand some features of the dynamics of the model. For several tree networks, we have done a sequence of calculations for different values of the minimal generator power margin $(\Delta P/P)_c$ at a constant g . We have changed this margin from 0 to 100%. For each value of this parameter, we have carried out the calculations for more than 100 000 days in a steady state regime. One way of looking at the change of characteristic properties of the blackouts with Γ is by plotting the power delivered and the averaged number of line outages per blackout. For a 94-node tree network, these plots are shown in Fig. 7. We can see that at low and high values of Γ , the power served is low. In the first case, because of the limited generator power, the system cannot deliver enough power when there is a relatively large fluctuation in load demand. At high Γ , the power served is low because the number of line outages per blackout is large.

Looking at averaged quantities is not a good way of identifying the demarcation between single failures and cascading events. To have a better sense of this demarcation, we have calculated the PDF of the number of line outages per blackout. In Fig. 8, we have plotted these PDFs for different values of Γ . The calculation was done for a 94-node tree network. We can see that at very low Γ there is a clear peak at 4 outages per blackout with very low probability for blackouts with more than 10 outages per blackout. As Γ in-

creases, a second peak at about 17 outages emerges and the height of the peak increases with Γ . At the highest Γ value, this second peak is comparable to the peak at low number outages per blackout. In Fig. 9, we have plotted the ratio of the frequency of blackouts with more than 15 outages to the mean frequency of blackouts. We can see that for $\Gamma > 1$, this ratio reaches 0.007. This gives a measure of the frequency of what we can consider large-scale blackouts (more than 16%




FIG. 7. (Color) Averaged power delivered and number of line outages per blackout for the 94-node tree network as a function of Γ

TABLE I. Power law exponent of the PDF of the normalized power shed.

Number of nodes	PDF decay index	Range of power tail
46	-0.56	4
94	-0.51	8
190	-0.55	13
382	-0.58	31




FIG. 8. (Color) PDF of the number of outages per blackout for the 94-node tree network for different values of Γ .

of the whole grid). We can apply this result to the U.S. grid, taking into account that the average frequency of blackouts is one every 13 days. In the low- Γ regime, the ratio is about 0.001; this would imply that a large scale blackout is likely every 35 years. In the high- Γ regime, the ratio goes up to 0.007; this implies a frequency of one large-scale blackout every 5 years.




FIG. 9. (Color online) Ratio of the frequency of blackouts with more than 15 outages to the frequency of blackouts for the 94-node tree network as a function of Γ .

V. CONCLUSIONS

The simple mechanisms introduced into the power transmission model and representing the economical and engineering responses to increasing power demands are sufficient to introduce a complex behavior in the power system. The results of the complex dynamics, time correlations, and PDFs of blackout sizes are consistent with the available data on blackouts of the North American electrical grid.

This model suggests that the real cause of the blackouts in the electric power system should not be identified just with the immediate random events that trigger them; instead, the real underlying cause is at a deeper level in the long-term forces that drive the evolution of the power system.

An important parameter in the system, Γ , is the ratio of the generator margin capability to the maximum daily fluctuation of the loads. This is a surrogate for the systems ability to absorb fluctuations. We do not yet have an economic model for the time evolution of Γ which would be the next level of self-consistent evolution for the system. This parameter allows us to classify the dynamics of the model into two regimes. At low Γ , blackouts and brownouts are frequent, and a typical blackout is characterized by very few line outages. For $\Gamma > 1$, blackouts are less frequent, but large cascading events involving many line outages are possible.

The dynamical behavior of this model has important implications for power system planning and operation and for the mitigation of blackout risk. The present model has some of the characteristic properties of a SOC system, although one cannot unequivocally prove that is strictly the case. The success of mitigation efforts in complex systems is strongly influenced by the dynamics of the system. One can understand the complex dynamics as including opposing forces that drive the system to a “dynamic equilibrium” near criticality in which disruptions of all sizes occur. Power tails are a characteristic feature of this dynamic equilibrium. Unless the mitigation efforts alter the self-organizing dynamical forces driving the system, the system may be pushed toward criticality. To alter those forces with mitigation efforts may be quite difficult because the forces are an intrinsic part of our society and therefore the power system. Therefore, we expect that feasible mitigation efforts can move the system to a new dynamic equilibrium which will remain near criticality and preserve the power tails.⁵ Thus, while the absolute frequency of disruptions of all sizes may be reduced, the underlying forces can still cause the relative frequency of large blackouts to small blackouts to remain the same.

ACKNOWLEDGMENTS

I.D. and D.E.N. gratefully acknowledge support in part from NSF Grants Nos. ECS-0216053 and ECS-0214369. I.D. and B.A.C. gratefully acknowledge coordination of part of this work by the Consortium for Electric Reliability Technology Solutions and funding in part by the Assistant Secretary for Energy Efficiency and Renewable Energy, Office of Power Technologies, Transmission Reliability Program of the U.S. Department of Energy under Contract No. 9908935 and Interagency Agreement No. DE-A1099EE35075 with the National Science Foundation. Part of this research has

been carried out at Oak Ridge National Laboratory, managed by UT-Battelle, LLC, for the U.S. Department of Energy under Contract No. DE-AC05-00OR22725.

APPENDIX

The blackout model is based on the standard dc power flow equation,

$$F = AP, \quad (A1)$$

where F is a vector whose N_L components are the power flows through the lines, F_{ij} , P is a vector whose $N_N - 1$ components are the power of each node, P_i , with the exception of the reference generator, P_0 , and A is a constant matrix. The reference generator power is not included in the vector P to avoid singularity of A as a consequence of the overall power balance.

The input power demands are either specified deterministically or as an average value plus some random fluctuation around the average value. The random fluctuation is applied to either each load or to "regional" groups of load nodes.

The generator power dispatch is solved using standard LP methods. Using the input power demand, we solve the power flow equations, Eq. (A1), with the condition of minimizing the following cost function:

$$\text{Cost} = \sum_{i \in G} P_i(t) - W \sum_{j \in L} P_j(t). \quad (A2)$$

We assume that all generators run at the same cost and that all loads have the same priority to be served. However, we set up a high price for load shed by setting W at 100. This minimization is done with the following constraints:

- (1) Generator power $0 \leq P_i \leq P_i^{\max}$ $i \in G$,
- (2) Load power $P_j \leq 0$ $j \in L$,
- (3) Power flows $|F_{ij}| \leq F_{ij}^{\max}$,
- (4) Power balance $\sum_{i \in G \cup L} P_i = 0$.

This linear programming problem is numerically solved by using the simplex method as implemented in Ref. 25. The assumption of uniform cost and load priority can of course be relaxed, but changes to the underlying dynamics are not likely from this.

In solving the power dispatch problem for low-load power demands, the initial conditions are chosen in such a way that a feasible solution of the linear programming problem exists. That is, the initial conditions yield a solution without line overloads and without power shed. Increases in the average load powers and random load fluctuations can cause a solution of the linear programming with line overloads or requiring load power to be shed. At this point, a cascading event may be triggered.

A cascading overload may start if one or more lines are overloaded in the solution of the linear programming problem. We consider a line to be overloaded if the power flow through it is within 1% of F_{ij}^{\max} . At this point, we assume that there is a probability p_1 that an overloaded line will cause a line outage. If an overloaded line experiences an

outage, we reduce its corresponding F_{ij}^{\max} by a large amount (making it effectively zero) to simulate the outage, and calculate a new solution. This process can require multiple iterations and continues until a solution is found with no more outages.

This fast dynamics model does not attempt to capture the intricate details of particular blackouts, which may have a large variety of complicated interacting processes also involving, for example, protection systems, and dynamics and human factors. However, the fast dynamics model does represent cascading overloads and outages that are consistent with some basic network and operational constraints.

¹D. N. Ewart, IEEE Spectrum **15**, 36 (1978).

²B. A. Carreras, D. E. Newman, I. Dobson, and A. B. Poole, "Evidence for self-organized criticality in electric power system blackouts" (to be published).

³J. Chen, J. S. Thorp, and M. Parashar, "Analysis of electric power disturbance data," 34th Hawaii International Conference on System Sciences, Maui, Hawaii, January 2001.

⁴Information on electric systems disturbances in North America can be downloaded from the NERC website at <http://www.nerc.com/dawg/database.html>.

⁵B. A. Carreras, V. Lynch, I. Dobson, and D. E. Newman, "Blackout mitigation assessment in power transmission systems," 36th Hawaii International Conference on System Sciences, Hawaii, January 2003. Available from IEEE at <http://ieeexplore.ieee.org>.

⁶I. Dobson, B. A. Carreras, V. Lynch, and D. E. Newman, "An initial model for complex dynamics in electric power system blackouts," 34th Hawaii International Conference on System Sciences, Maui, Hawaii, January 2001. Available from IEEE at <http://ieeexplore.ieee.org>.

⁷B. A. Carreras, D. E. Newman, I. Dobson, and A. B. Poole, "Modeling blackout dynamics in power transmission networks with simple structure," 34th Hawaii International Conference on System Sciences, Maui, Hawaii, January 2001. Available from IEEE at <http://ieeexplore.ieee.org>.

⁸B. A. Carreras, V. Lynch, I. Dobson, and D. E. Newman, Chaos **12**, 985 (2002).

⁹P. Bak, C. Tang, and K. Wiesenfeld, Phys. Rev. Lett. **59**, 381 (1987).

¹⁰M. L. Sachtjen, B. A. Carreras, and V. E. Lynch, Phys. Rev. E **61**, 4877 (2000).

¹¹J. Chen and J. S. Thorp, "A reliability study of transmission system protection via a hidden failure DC load flow model," IEEE Fifth International Conference on Power System Management and Control, 17–19 April 2002, pp. 384–389.

¹²J. Chen, J. S. Thorp, and I. Dobson, "Cascading dynamics and mitigation assessment in power system disturbances via a hidden failure model," preprint (to be published).

¹³M. D. Stubna and J. Fowler, Int. J. Bifurcation Chaos Appl. Sci. Eng. **13**, 237 (2003).

¹⁴S. Roy, C. Asavathiratham, B. C. Lesieutre, and G. C. Verghese, "Network models: Growth, dynamics, and failure," in Proceedings of the 34th Annual Hawaii International Conference on System Sciences, 3–6 January 2001, pp. 728–737.

¹⁵D. L. Pepyne, C. G. Panayiotou, C. G. Cassandras, and Y.-C. Ho, "Vulnerability assessment and allocation of protection resources in power systems," in Proceedings of the American Control Conference, Vol. 6, 25–27 June 2001, pp. 4705–4710.

¹⁶C. L. DeMarco, "A phase transition model for cascading network failure," IEEE Control Syst. Mag. **21**, 40–51 (2001).

¹⁷P. A. Parrilo, S. Lall, F. Paganini, G. C. Verghese, B. C. Lesieutre, and J. E. Marsden, "Model reduction for analysis of cascading failures in power systems," in Proceedings of the 1999 American Control Conference, Vol. 6, 2–4 June 1999, pp. 4208–4212.

¹⁸B. Stott and E. Hobson, IEEE Trans. Power Appar. Syst. **PAS-97**, 1713 (1978).

¹⁹B. Stott and E. Hobson, IEEE Trans. Power Appar. Syst. **PAS-97**, 1721 (1978).

²⁰B. Stott and J. L. Marinho, IEEE Trans. Power Appar. Syst. **PAS-97**, 837 (1979).

- ²¹The IEEE 118 bus network model is a standard test system; see <http://www.ee.washington.edu/research/pstca/>.
- ²²Statistical Yearbook of the electric utility industry/1998, published by Edison Electric Institute (1998).

- ²³H. E. Hurst, *Trans. Am. Soc. Civ. Eng.* **116**, 770 (1951).
- ²⁴B. B. Mandelbrot and J. R. Wallis, *Water Resour. Res.* **4**, 909 (1969).
- ²⁵W. H. Press, B. P. Flannery, S. A. Teukolsky, and W. T. Vetterling, *Numerical Recipes in C* (Cambridge University Press, Cambridge, 1988).